

REGISTERED CSA GROUP  
CRN: CSA-OC21554.56  
Registration Process administered by CSA Group per CSA B51

Statutory Declaration Registration of Fittings

(a) Design Qualification

I, Joel Feldman  
Vice President, Engineering  
*(Position eg, president, plant manager, chief eng.)*

Of Swagelok Company  
*(name of company)*

Located at Headquarters: 29500 Solon Road, Solon, Ohio 44139 USA (See Attachment A)  
*(plant address)*

do solemnly declare that the fittings listed hereunder, which are subject to the Boilers & Pressure Vessels Act

- comply with all the requirements of the ANSI/ASME codes as to their dimensions, material, identification & service for which are required:
- Or
- are not covered by the provisions of the ANSI/ASME codes, and are therefore constructed to comply with \_\_\_\_\_ code and standard, and are designed to the best current engineering practice, as shown by the supporting test data.



(b) Quality control of Manufacture

I further declare the manufacture of these fittings is controlled by a quality control program which complies with the requirements of ISO 9001:2015, and has been verified by the following authority or authorized agency BSI

The fittings<sup>2</sup> covered by this declaration, for which I seek registration, are Category C. Valve

In support of the application, the following information, calculations and/or test data are attached:  
ISO 9001:2015 Certificate, Attachment A, Attachment B, Catalog Information and other Support Documents

Declared before me at Solon  
In the of State of Ohio  
The Day of July AD 20 19  
Brenda Harnel  
*(Commissioner for oaths)*

Joel C. Feldman  
*Signature of Declarer*

For Official Use Only

The application is accepted for registration in Category C in accordance with the Boilers and Pressure Vessels Act and CSA Standard B51.

This registration must be revalidated after ten (10) years from the date of acceptance. July . 5 . 2029

Registered Number CRN CSA-OC21554.56

For the Chief Inspector A. BANWATT  
Date JUL 31 2019

- Three completed copied of Statutory Declaration form together with three copies of Catalogs, drawings of Bulletins illustrating above fittings shall be submitted.
- All fittings are required to be registered in the name of the Manufacturer.
- This form shall be completed and signed by the president of highest official in the manufacturing plan where the fitting is produced.




## Attachment B: Scope of CRN Registration for Swagelok CP and CPA Series Check Valves (Category C)


This document represents the scope of the CP and CPA Series Check Valves covered by this submission for CRN approval. The Swagelok CP and CPA Series Check Valves were designed and evaluated in accordance with ASME B31.1-2016 for unlisted components and ASME B31.3-2016 for unlisted components.

### Summary Table

Product Series	Main Pressure Bearing Component	Main Pressure Bearing Material (Standard)	Port Connections and Sizes	Maximum Rated Pressure		Design Code of Construction
				At -50 to 100°F	@ max. temperature	
4CP	Body	316 SS (ASTM A479)	Female NPT 1/4" Male NPT 1/4" Female ISO 1/4" Male ISO 1/4"	3000 psi @ 100°F	2185 psi @ 375°F	ASME B31.1 (Unlisted Components) and ASME B31.3 (Unlisted Components)
8CP	Body	316 SS (ASTM A479)	Female NPT 1/2" Male NPT 1/2"	3000 psi @ 100°F	2185 psi @ 375°F	
4CP	Body	Brass C36000 (ASTM B16)	Female NPT 1/4" Male NPT 1/4" Female ISO 1/4" Male ISO 1/4"	3000 psi @ 100°F	2405 psi @ 250°F	
8CP	Body	Brass C36000 (ASTM B16)	Male NPT 1/2"	3000 psi @ 100°F	2405 psi @ 250°F	
			Female NPT 1/2"	2400 psi @ 100°F	2085 psi @ 250°F	
4CPA	Body	316 SS (ASTM A479)	Female NPT 1/4" Male NPT 1/4" Male ISO 1/4"	3000 psi @ 100°F	2185 psi @ 375°F	
8CPA	Body	316 SS (ASTM A479)	Male NPT 1/2" Male ISO 1/2"	3000 psi @ 100°F	2185 psi @ 375°F	
4CPA	Body	Brass C36000 (ASTM B16)	Female NPT 1/4" Male NPT 1/4" Male ISO 1/4"	3000 psi @ 100°F	2405 psi @ 250°F	
8CPA	Body	Brass C36000 (ASTM B16)	Male NPT 1/2" Male ISO 1/2"	3000 psi @ 100°F	2405 psi @ 250°F	


  
**ATTACHMENT TO**  
**CRN CSA-0021554.5**  
 Signed: *[Signature]*  
 180 Adelaide Boulevard, Toronto, ON Canada M9W 1R3

## Product Illustration



CSA-OC21554.56

## Product Options:

Some product options could affect the pressure-temperature ratings shown in the Summary Table, but in all cases the ratings are less than those shown in the Summary Table. Examples of these would include poppet springs and seat O-ring materials.


## Quality System

The Swagelok Company quality system complies with the requirements of ISO 9001:2015. The Swagelok Company maintains BSI Certificate of Registration Number FM 01729, which applies to all locations listed on the Certificate.

## References

The product catalog does not represent the full scope of registration, but rather details some of the most common options.

- Check Valve Catalog MS-01-176, R11



CSA-OC21554.56

## Attachment A. Swagelok Manufacturing Locations

This document lists the Swagelok locations where end item or component level manufacturing activities take place.

Swagelok Company 29500 Solon Road Solon, Ohio 44139 USA	Swagelok Company (Falon 1) 348 Bishop Road Highland Heights, Ohio 44143 USA
Swagelok Company (Highland) 318 Bishop Road Highland Heights, Ohio 44143 USA	Swagelok Company (Falon 2) 358 Bishop Road Highland Heights, Ohio 44143 USA
Swagelok Company (OFC) 29495 F.A. Lennon Drive Solon, Ohio 44139 USA	Swagelok Company (HPF) 6050 Cochran Road Solon, Ohio 44139 USA
Swagelok Company (Atlantic) 26651 Curtiss Wright Parkway Willoughby Hills, Ohio 44092 USA	Swagelok Company (Snow Metal) 6060 Cochran Road Solon, Ohio 44139 USA
Swagelok Company (Micro) 26653 Curtiss Wright Parkway Willoughby Hills, Ohio 44092 USA	Swagelok Company (Alfred) 29500 Ambina Drive Solon, Ohio 44139
Swagelok Hose Services Company (SHSC) 29900 Solon Industrial Parkway Solon, Ohio 44139	Swagelok Company (Strongsville) 15400 Foltz Road Strongsville, Ohio 44119
Swagelok (China) Fluid System Technologies Ltd. Changshu Export Process Zone Changshu Economic Development Zone Changshu, Jiangshu 215513 China	Swagelok Limited Ballafletcher Road Tromode IM4 4RA Isle of Man

